



City of Virginia Beach

VBgov.com

OFFICE OF THE CITY ENGINEER
(757) 385-4131
FAX (757) 385-5668

MUNICIPAL CENTER
BUILDING 2
2405 COURTHOUSE DRIVE
VIRGINIA BEACH, VIRGINIA 23456-9031

May 15, 2006

Mr. Graham Bryant, P.E.
President
Hydroworks
525 Boulevard
Kenilworth, NJ 07033

Re: Product Approval

Dear Mr. Bryant:

The City of Virginia Beach Product Evaluation Committee has completed our review of the Hydroguard. We hereby **APPROVE** the Hydroguard for use in the City of Virginia Beach.

The Hydroguard is eligible for a rating of 20% CBPA Phosphorous removal, until we have actual field test data from local sites that show a higher rating is achievable. In addition, this product qualifies the owner for a 10% reduction in storm water utility billings. The City will consider increasing this reduction if an increased removal rating at an approved local site, can be shown.

Please do not hesitate to contact me if you have any questions or comments regarding this matter.

Sincerely,

Phillip D. Pullen, P.E.
Product Evaluation Committee Chairman

PDP/po

C: Karl Smithson
Cheryl Cole
Charlie Heffington