



U.S. Patent No. 6,951,619

Dimensions in millimeters  
 Permanent Pool Volume = 1700 Liters  
 The Hydroguard must be cleaned after the construction period if used as a sediment and erosion control measure  
 The Hydroguard should be inspected once per year on stabilized sites  
 Inspection will determine the maintenance frequency (annual maintenance or every 2 years typical for stabilized sites)  
 Sites with unstable conditions (exposed soil or materials storage) will require more frequent inspection and maintenance

Hydroworks, LLC  
 50 S 21st St., Kenilworth, NJ 07033  
 Phone: 888-290-7900 Fax: 888-783-7271  
 Web: www.hydroworks.com

Hydroworks HG4 (1200mmØ)	
PROJECT:	
LOCATION:	
REVISION DATE:	05/03/2011

