



U.S. Patent No. 6,951,619

Dimensions in inches
 Permanent Pool Volume = 800 US gallons
 The Hydroguard must be cleaned after the construction period
 if it is used as a sediment and erosion control measure
 The Hydroguard should be inspected once per year for
 stabilized sites
 Inspection will determine the maintenance frequency (annual
 maintenance or once every two years typical for stabilized
 sites)
 Sites with unstable conditions (exposed soil or materials
 storage) will require more frequent inspection and maintenance

Hydroworks, LLC
 50 S. 21st St., Kenilworth, NJ 07033
 Phone: 888-290-7900 Fax: 888-783-7271
 Web: www.hydroworks.com

Hydroworks HG5 (60"Ø)
PROJECT:
LOCATION:
REVISION DATE: 02/10/2011

